

DISCHARGER: WEAVERVILLE
 SELF MONITORING REPORT FOR THE YEAR OF: 2008

REQUIREMENTS COMPLIANCE SUMMARY

MONTH	FLOW MGD MAX	FLOW MGD MEAN	CL2 MG/L MAX	PH MAX 8.5	PH MIN 6.5	SETTLE SOLIDS MG/L MAX 0.2	SETTLE SOLIDS MG/L MEAN 0.1	D.O. MG/L MIN 1	B.O.D. MG/L MAX 60	B.O.D. MG/L MEAN 30	NFR MG/L MAX 60	NFR MG/L MEAN 30	COLLIFORM 100 MLS/MPN MAX 230	COLLIFORM 100 MLS/MPN MEDIAN 23
JANUARY	1.095	0.611	0.9	7.21	7.09	<MDL	<MDL	6.18	13.00	10.33	16	13	5	5
FEBRUARY	0.655	0.505	0.4	7.22	7.08	<MDL	<MDL	5.62	8.85	6.63	13	10	2	2
MARCH	0.385	0.302	1.0	7.26	6.88	<MDL	<MDL	6.28	7.13	6.29	13	9	5	4
APRIL	0.315	0.255	0.1	7.24	7.06	<MDL	<MDL	5.28	17.79	5.19	21	13	5	4
MAY														
JUNE														
JULY														
AUGUST														
SEPTEMBER														
OCTOBER														
NOVEMBER														
DECEMBER														

X

Jim Cloud
 General Manager