

DISCHARGER: WEAVERVILLE
 SELF MONITORING REPORT FOR THE YEAR OF: 2008

REQUIREMENTS COMPLIANCE SUMMARY

MONTH	FLOW MGD MAX	FLOW MGD MEAN	CL2 MG/L MAX	PH MAX	PH MIN	SETTLE SOLIDS MG/L MAX	SETTLE SOLIDS MG/L MEAN	D.O. MG/L MIN	B.O.D. MG/L MAX	B.O.D. MG/L MEAN	NFR MG/L MAX	NFR MG/L MEAN	COLLIFORM 100 MLS/MPN MAX	COLLIFORM 100 MLS/MPN MEDIAN
				8.5	6.5	0.2	0.1	1	60	30	60	30	230	23
JANUARY	1.095	0.611	0.9	7.21	7.09	<MDL	<MDL	6.18	13.00	10.33	16	13	5	5
FEBRUARY	0.655	0.505	0.4	7.22	7.08	<MDL	<MDL	5.62	8.85	6.63	13	10	2	2
MARCH														
APRIL														
MAY														
JUNE														
JULY														
AUGUST														
SEPTEMBER														
OCTOBER														
NOVEMBER														
DECEMBER														

X

Jim Cloud
 General Manager