

DISCHARGER: WEAVERVILLE - ID NUMBER 1A840720TRI

SELF MONITORING REPORT FOR THE YEAR OF: 2008

REQUIREMENTS COMPLIANCE SUMMARY

MONTH	FLOW MGD MAX	FLOW MGD MEAN	CL2 MG/L MAX	PH MAX	PH MIN	SETTLE SOLIDS MG/L MAX	SETTLE SOLIDS MG/L MEAN	D.O. MG/L MIN	B.O.D. MG/L MAX	B.O.D. MG/L MEAN	NFR MG/L MAX	NFR MG/L MEAN	COLLIFORM 100 MLS/MPN MAX	COLLIFORM 100 MLS/MPN MEDIAN
DISCHARGE LIMITS				8.5	6.5	0.2	0.1	1	60	30	60	30	230	23
JANUARY	1.095	0.611	0.9	7.21	7.09	<MDL	<MDL	6.18	13.00	10.33	16	13	5	5
FEBRUARY	0.655	0.505	0.4	7.22	7.08	<MDL	<MDL	5.62	8.85	6.63	13	10	2	2
MARCH	0.385	0.302	1.0	7.26	6.88	<MDL	<MDL	6.28	7.13	6.29	13	9	5	4
APRIL	0.315	0.255	0.1	7.24	7.06	<MDL	<MDL	5.28	17.79	5.19	21	13	5	4
MAY	0.359	0.298	0.1	7.28	6.97	<MDL	<MDL	2.80	10.73	8.99	13	11	5	4
JUNE														
JULY														
AUGUST														
SEPTEMBER														
OCTOBER														
NOVEMBER														
DECEMBER														

X

Jim Cloud
General Manager