

Weaverville Sanitary District

P.O. Box 1269 Weaverville, CA 96093

Telephone – Office: (530) 623-4102 – Treatment Plant: (530) 623-6529 – Fax: (530) 623-1975

<http://www.weavervillesd.com>

NPDES WDR Self Monitory Report for the month of April, 2009

**California Regional Water Quality Control Board, North Coast Region
ID Number 1A840720TRI**

Attached: Discharge Summary

I certify under penalty of law that this document and all attached documents were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

X

Jim Cloud
General Manager

DISCHARGER: WEAVERVILLE
 SELF MONITORING REPORT FOR THE YEAR OF: 2009

REQUIREMENTS COMPLIANCE SUMMARY

| MONTH | FLOW MGD MAX | FLOW MGD MEAN | CL2 MG/L MAX | PH MAX 8.5 | PH MIN 6.5 | SETTLE SOLIDS MG/L MAX 0.2 | SETTLE SOLIDS MG/L MEAN 0.1 | D.O. MG/L MIN 1 | B.O.D. MG/L MAX 60 | B.O.D. MG/L MEAN 30 | NFR MG/L MAX 60 | NFR MG/L MEAN 30 | COLLIFORM 100 MLS/MPN MAX 230 | COLLIFORM 100 MLS/MPN MEDIAN 23 |
|-----------|--------------------|---------------------|--------------------|------------------|------------------|--|---|--------------------------|-----------------------------|------------------------------|--------------------------|---------------------------|--|--|
| JANUARY | 0.388 | 0.289 | 0.3 | 7.16 | 7.01 | <MDL | <MDL | 6.31 | 11.59 | 9.44 | 16 | 14 | 1 | 1 |
| FEBRUARY | 0.638 | 0.366 | 0.4 | 7.34 | 6.70 | <MDL | <MDL | 7.06 | 11.69 | 7.13 | 10 | 9 | 4 | 1 |
| MARCH | 0.469 | 0.310 | 0.3 | 7.16 | 7.01 | <MDL | <MDL | 4.30 | 8.25 | 4.71 | 11 | 9 | 5 | 2 |
| APRIL | 0.355 | 0.257 | 0.2 | 7.19 | 6.97 | <MDL | <MDL | 5.61 | 13.50 | 9.19 | 261 | 63 | 1 | 1 |
| MAY | | | | | | | | | | | | | | |
| JUNE | | | | | | | | | | | | | | |
| JULY | | | | | | | | | | | | | | |
| AUGUST | | | | | | | | | | | | | | |
| SEPTEMBER | | | | | | | | | | | | | | |
| OCTOBER | | | | | | | | | | | | | | |
| NOVEMBER | | | | | | | | | | | | | | |
| DECEMBER | | | | | | | | | | | | | | |

X

Jim Cloud
General Manager