

# Weaverville Sanitary District

*P.O. Box 1269 Weaverville, CA 96093*

*Telephone – Office: (530) 623-4102 – Treatment Plant: (530) 623-6529 – Fax: (530) 623-1975*

*<http://www.weavervillesd.com>*

---

## **NPDES WDR Self Monitory Report for the month of November, 2009**

**California Regional Water Quality Control Board, North Coast Region  
ID Number 1A840720TRI**

**Attached: Discharge Summary**

**I certify under penalty of law that this document and all attached documents were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.**

**X**

---

Jim Cloud  
General Manager

DISCHARGER: WEAVERVILLE  
 SELF MONITORING REPORT FOR THE YEAR OF: 2008

REQUIREMENTS COMPLIANCE SUMMARY

MONTH	FLOW MGD MAX	FLOW MGD MEAN	CL2 MG/L MAX	PH MAX 8.5	PH MIN 6.5	SETTLE SOLIDS MG/L MAX 0.2	SETTLE SOLIDS MG/L MEAN 0.1	D.O. MG/L MIN 1	B.O.D. MG/L MAX 60	B.O.D. MG/L MEAN 30	NFR MG/L MAX 60	NFR MG/L MEAN 30	COLLIFORM 100 MLS/MPN MAX 230	COLLIFORM 100 MLS/MPN MEDIAN 23
JANUARY	0.388	0.289	0.3	7.16	7.01	<MDL	<MDL	6.31	11.59	9.44	16	14	1	1
FEBRUARY	0.638	0.366	0.4	7.34	6.70	<MDL	<MDL	7.06	11.69	7.13	10	9	4	1
MARCH	0.469	0.310	0.3	7.16	7.01	<MDL	<MDL	4.30	8.25	4.71	11	9	5	2
APRIL	0.355	0.257	0.2	7.19	6.97	<MDL	<MDL	5.61	13.50	9.19	16	13	1	1
MAY	0.591	0.297	0.3	7.28	6.84	<MDL	<MDL	7.84	6.55	5.75	10	9	16	15
JUNE	0.310	0.245	0.2	7.19	7.01	<MDL	<MDL	5.26	7.56	6.98	12	11	3	2
JULY	0.300	0.252	0.2	7.15	6.91	<MDL	<MDL	5.36	13.44	9.61	39	23	6	2
AUGUST	0.310	0.227	0.2	7.43	6.72	<MDL	<MDL	5.91	8.74	6.69	13	9	1	1
SEPTEMBER	0.346	0.238	0.2	7.28	7.06	<MDL	<MDL	5.86	9.12	7.08	11	9	23	2
OCTOBER	0.331	0.230	0.2	7.20	7.06	<MDL	<MDL	6.37	10.41	6.62	10	5	6	6
NOVEMBER	0.344	0.240	0.3	7.27	7.09	<MDL	<MDL	5.83	13.15	5.65	14	10	20	11
DECEMBER														

X

---

Jim Cloud  
 General Manager